

**Kay G. Love
City Administrator**

**Jere Wood
Mayor**

ADDENDUM 1

City of Roswell Purchasing Division

Request for Proposal #17-143-L

MAY 18, 2017

To All Prospective Offerors:

The Due Date remains to be 2:00 p.m. on Tuesday, May 23, 2017.

In reference to the RFP listed above, the following answers to questions, additions, deletions and changes are hereby incorporated into the Request for Proposal:

- 1. The scope of work for Grimes Bridge Skate Park & Roswell Area Park Courts 9 & 10 do not have lights under the scope of work? Will lights be needed for this project?
Answer: No lights will be needed at Grimes Bridge Skate Park. Lights are in place at Roswell Area Park courts 9 & 10.**
- 2. What permits will be required for this project and who is responsible for obtaining these permits?
Answer: The City will be responsible for the permitting for this project.**
- 3. Would this project allow an alternate pricing by providing a Slip-Sheet option for the below surface of the tennis courts?
Answer: Yes, an alternate pricing will be allowed.**
- 4. The typical size for a pickle ball court is 60' by 60', please confirm your desired dimensions for the court?
Answer: The pickle ball area should be 60'x60' for both pickle ball courts.**

5. Do you desire the pickle ball court to adjoin, with a shared fence, to the tennis court?

Answer: The pickle ball court and tennis court should be separated by a 10' tall black 8-gauge chain link fence with a walk through gate at each end.

6. What is the preferred access route for trucks and heavy equipment for the Roswell Area Park Courts 9 & 10?

Answer: The service road below the Tennis Center where the drainage ditch surrounds both sides of the tennis courts. There is a double wide gate on the far side of the picnic area.

COMPLETE THIS ADDENDUM, SIGN and SUBMIT with the ITB to:

**City of Roswell – Purchasing Division
Roswell City Hall
38 Hill Street, Suite 130
Roswell, GA 30075**

I hereby acknowledge receipt of Addendum 1 and have incorporated the changes into my proposal response for the above mentioned ITB.

COMPANY NAME: _____ CONTACT PERSON: _____

ADDRESS: _____ CITY: _____ STATE: _____ ZIP: _____

PHONE: _____ FAX: _____

EMAIL ADDRESS: _____

SIGNATURE: _____ DATE: _____



17-143-L

**Tennis Court Construction at Roswell Area Park
and Grimes Bridge Skate Park**

Alternate Cost Sheet for Slip Sheet Option
