

**City of Roswell
Purchasing Division**

**Gary Palmer
City Administrator**

**Lori Henry
Mayor**

ADDENDUM NUMBER 2

Invitation to Bid # 18-270-L

**HVAC Replacement
Roswell Area Park Physical Activity Center
October 17, 2018**

To All Prospective Offerors:

In reference to the ITB listed above, the following answers to questions are hereby incorporated into the Invitation to Bid:

Questions and Answers:

#	QUESTION	ANSWER
1.	Will Test and Balance be required?	Yes
2.	Will the line sets need to be replaced or can they be re-used?	Line sets can be re-used
3.	Does vendor need to add flexible connectors or hard piping into the coil for the hot and chill water piping?	Prefer hard piping to the Coils
4.	Will the drains need to be copper or PVC?	PVC
5.	Who is the Life Safety Contractor for the smoke alarm tie in?	MitecNet 2445 Meadowbrook Pkwy Duluth GA 30096

All other terms, conditions, and deadlines remain the same.

COMPLETE THIS ADDENDUM, SIGN and SUBMIT with the ITB to:

**City of Roswell – Purchasing Division
Roswell City Hall
38 Hill Street, Suite 130
Roswell, GA 30075**

I hereby acknowledge receipt of Addendum 2 and have incorporated the changes into my proposal response for the above mentioned ITB.

COMPANY NAME: _____ **CONTACT PERSON:** _____

ADDRESS: _____ **CITY:** _____ **STATE:** ____ **ZIP:** ____

PHONE: _____ **FAX:** _____ **EMAIL ADDRESS:** _____

SIGNATURE: _____ **DATE:** _____